

Contents

	Page
Foreword	v
1.6 Test	1
1.6.1 Scope	1
1.6.2 Types of tests	1
1.6.3 Terminology	1
1.6.4 Hydrostatic test	7
1.6.5 Performance test	9
1.6.6 Net positive suction head required test (optional)	19
1.6.7 Mechanical test (optional)	23
1.6.8 Priming time test	24
1.6.9 Measurement of rate of flow	25
1.6.10 Head — measurement	29
1.6.11 Power measurement	30
1.6.12 Speed measurement	31
1.6.13 Temperature measurement and instruments	32
1.6.14 Model tests	32
Appendix A References	35
Appendix B Index	36
Figures	
1.113 — Horizontal unit – (Single or double suction) (Double suction not shown)	4
1.114 — Vertical single suction pump	4
1.115 — Vertical double suction pump	4
1.116 — Test with suction lift	11
1.117 — Open or closed tank	13
1.118 — Pump performance (all data is corrected to rated speed)	16
1.119 — Suppression type NPSH test with constant level sump	19
1.120 — Level control NPSH test with deep sump supply	20
1.121 — Vacuum and/or heat control NPSH test with closed loop	20
1.122 — NPSH test with rate of flow held constant	21
1.123 — NPSH test with suction head held constant	21
1.124 — NPSH test with flow rate held constant	22
1.125 — Suction line for static lift test	25
1.126 — Pressure tap opening	26

1.127 — Welded-on pressure tap opening	26
1.128 — Single tap connection	29
1.129 — Loop manifold connecting pressure taps.	30
1.130 — Gauge connections	30

Tables

1.18 — Symbols.	2
1.19 — Subscripts	3
1.20 — Recommended instrument calibration interval	12
1.21 — Straight pipe required following any fitting before venturi meter in diameters of pipe	27
1.22 — Straight pipe required following any fitting before nozzle or orifice plate meter in diameters of pipe	28
1.23 — Straight pipe required following downstream pressure tap of a nozzle or orifice plate meter before any fitting in diameters of pipe	28