

Table of Contents

Foreword	xi
Acknowledgements	xiii
About the Hydraulic Institute	xvii
Europump	xvii
Executive Summary	xix
What is Life Cycle Cost?	xx
Getting Started	xxi
Introduction	xxiii

Chapter • One Life Cycle Cost, 1

1.1 General	1
1.2 Elements of Life Cycle Costs	3
1.2.1 Initial Cost (C_{ic})	3
1.2.2 Installation and Commissioning (Start-up) Cost (C_{in})	4
1.2.3 Energy Cost (C_e)	5
1.2.4 Operating Cost (C_o)	6
1.2.5 Maintenance and Repair Cost (C_m)	6
1.2.6 Downtime and Loss of Production Cost (C_s)	8
1.2.7 Environmental Cost, Including Disposal of Parts and Contamination from Pumped Liquid (C_{env})	8
1.2.8 Decommissioning and Disposal Cost, Including Restoration of the Local Environment (C_d)	8
1.3 Calculating Life Cycle Costs	9
1.3.1 General	9
1.3.2 Calculating Present Value (PV)	10
1.3.3 Calculation Chart Using the Simplified Method	11
1.3.4 Example Using the Manual Calculation Chart	14

Chapter • Two Pumping System Design, 17

2.1 General	17
2.2 System Design	17
2.2.1 Pipe Size	17
2.2.2 Pump and System Curves	18
2.3 Output Control	20

2.4	Pump Type Selection	20
2.4.1	Pump Types	20
2.4.2	Ways to Reduce LCC When Selecting Pumps	28
2.5	Selecting a Driver.	36
2.5.1	Background	36
2.5.2	Types of Electric Motors	36
2.5.3	Efficiency and Energy Costs	38
2.5.4	Variable Frequency Drives	39
2.6	Auxiliary Services.	40
2.6.1	Cooling Services	40
2.6.2	Heating	41
2.6.3	Seal Flush Systems.	41
2.6.4	Seal Quench Systems.	42
2.6.5	Barrier Fluid Systems	42
2.6.6	Lubrication Systems for Sleeve Bearings	42
2.7	Power Transmission	42
2.7.1	Summary of Power Transmission Characteristics.	42
2.8	System Effectiveness in Design and Output Control: A New Concept	43
2.8.1	Process Requirements	43
2.8.2	Specific Energy	47
2.8.3	Summary	52
2.9	Monitoring and Sustaining the System	53
2.9.1	Maintaining Pump Efficiency	53
2.9.2	Organizing Maintenance and Monitoring.	60

Chapter • Three
**Methods for Analyzing
Existing Pumping Systems, 63**

3.1	Introduction	63
3.2	Improving the System	63
3.3	System Components	64
3.3.1	Pump	64
3.3.2	Control or Throttle Valves	65
3.3.3	Components	65
3.4	System Loads	66
3.5	Determining the Rates of Flow.	66
3.6	Example of Minimizing Losses by Balancing a Branched System.	67
3.6.1	Balancing the System	67
3.6.2	Changing the Pump.	69

3.7 Examples for Achieving Energy Savings in Existing Systems	71
3.7.1 Example 1: Waste Collection System With Oversized Pumps	71
3.7.2 Example 2: System With a Problem Control Valve.	75

Chapter • Four

Examples of LCC Analysis, 79

4.1 Waste Collection System Example	79
4.2 Problem Control Valve Example	80

Chapter • Five

Effective Procurement Using LCC, 91

5.1 Introduction	91
5.2 Enquiry Documentation.	91
5.3 Evaluation Sum.	92
5.4 Work Methodology	92
5.5 Contract Boundaries	93
5.6 Evaluating Tenders	93
5.7 Inspection - Performance Bonus or Penalty	93
5.8 Example	93

Chapter • Six

Recommendations for Designing and Procuring Pumping Systems, 95

Chapter • Seven

References, 99

Chapter • Eight

Glossary of Terms and Symbols, 103

Appendix A

System Curves, 105

A.1 System Curves	105
A.1.1 Operating Duty Point	105

A.1.2	Characteristic Curves	105
A.1.3	Branched Piping Systems	117
A.1.4	Duty Modifications	121
A.1.5	Viscous and Non-Newtonian Liquids	124
A.2	Computer Software	125

Appendix B

Pumping Output and System Control, 127

B.1	Output Control	127
B.1.1	General.	127
B.1.2	Determining Flow Requirements	128
B.2	System Control	131
B.2.1	Control Parameters	132
B.2.2	Start–Stop Control	134
B.2.3	Throttling Control	137
B.2.4	Variable Speed Regulation.	138
B.2.5	Eccentric Radius Adjustment in Vane Cell Pumps.	141
B.2.6	Stroke and Speed Regulation of Reciprocating Positive Displacement Pumps	141
B.3	Summary	142

Appendix C

Pump Efficiencies, 145

C.1	Pump Efficiencies	145
C.1.1	General.	145
C.1.2	Nomenclature	147

Appendix D

Case Histories–Cost Savings Examples, 149

D.1	Introduction	149
	Case History 1: Building services.	152
	Case History 2: Pulp and paper manufacture.	154
	Case History 3: Chemical processing.	156
	Case History 4: Water supply.	158
	Case History 5: Waste water.	160
	Case History 6: Steel making.	162
	Case History 7: Petrochemical processing.	164
	Case History 8: Domestic electrical appliance.	166
	Case History 9: Mining.	168
	Case History 10: Power plant.	170

Case History 11: Building services.....	172
Case History 12: Building services.....	173
Case History 13: Chemical industry.....	175
Case History 14: Food industry.....	177

Appendix E

Drivers and Transmissions, 179

E.1 Electric Motor Efficiency	179
E.1.1 European Policies	179
E.1.2 North American Policies	180
E.1.3 Losses in Motors	181
E.1.4 Submersible Motor Efficiency	182
E.1.5 Energy Cost Calculation	182
E.1.6 Motors for Circulators in Heating Systems	183
E.1.7 Variable Frequency Drives	184
E.1.8 Repair or Replace?	186
E.2 Power Transmission	187
E.2.1 Efficiency and Characteristics of Various Types of Transmissions.....	187
E.2.2 Summary.....	194

List of Figures

Typical LCC for a medium-sized industrial pumping system.....	xvi
1.1 Manual calculation chart of LCC	15
1.2 Example 4.1.b using the manual calculation chart	16
2.1 Key cost components for a pumping installation as related to pipe size.....	18
2.2 Typical pump performance and system curves – rotodynamic pumps	19
2.3 Typical pump performance and system curves – positive displacement pumps.....	19
2.4 Pump selection diagram for rotodynamic pumps with standard drivers handling clean liquids	23
2.5 Average attainable industrial pump efficiency, η_{avg} , for rotodynamic volute pumps with closed impellers and for clean cold water (see Appendix C).....	24
2.6 Typical pump selection diagram for positive displacement pumps (PD pumps)	25
2.7a Maximum attainable efficiencies for PD pumps with fluids below 100 mPa s	26

2.7b	Maximum attainable efficiencies for PD pumps with fluids below 1000 mPa s.	27
2.8	Indication of the influence of viscosity on the efficiency for different types of PD pumps	28
2.9	Example of a performance curve for a rotodynamic pump showing the preferred operating region	29
2.10	Variations in efficiency for a 30-kW 4-pole motor.	38
2.11	Efficiency curve of a typical variable frequency drive	39
2.12	Duration diagrams for two different pumping systems	44
2.13	System curve	45
2.14	Lines of constant efficiency (broken) superimposed over speed-regulated pump curves (solid)	46
2.15	The operating point on the reduced speed curve moves relatively higher on the pump curve as the speed is reduced	46
2.16	Example of specific energy as a function of static head and overall efficiency	49
2.17	Three different system curves A, B and C, all passing through the same duty point at full speed and the associated curves for specific energy.	50
2.18	Throttling a valve changes the rate of flow by adding pressure drop in the valve, thus moving the duty point along the pump curve	51
2.19	Compared with regulation by throttling, variable speed drives always save on energy.	51
2.20	Parallel pump operation	52
2.21	Reduced efficiency and head caused by leakage losses	54
2.22	Clearances from left to right: semi-open impeller clearance; closed impeller radial clearance; closed impeller axial clearance	54
2.23	Examples of clearances (s) in rotating positive displacement pumps: a) screw pump; b) gear pump	58
2.24	Pressure signals of a hydraulically acting diaphragm pump: a) healthy pressure signal; b) leakage in the hydraulic chamber (replenishing window [RW])	59
2.25	Structure-borne noise signal and pressure signal of a reciprocating PD pump: a) healthy pump; b) leaking suction valve.	59
2.26	Preventive maintenance in terms of total maintenance costs.	61

3.1	Branched piping system showing the rate of flow in the various paths	67
3.2	Branched system showing the differential pressure in bar across the throttle valves needed to throttle the rate of flow to the set value	68
3.3	The branched piping system with flows balanced and pump impeller trimmed to eliminate excessive differential pressure across the control valves	69
3.4	The pump curve for the larger and smaller impeller trim; rate of flow for unbalanced flow is 166 m ³ /h (720 USgpm), balanced rate of flow 120 m ³ /h (520 USgpm)	70
3.5	Pressurized forced main system pumping down the sump using on/off control; evaluating changing pumping rate for lower operating costs	71
3.6	Total head as a function of rate of flow for the sump pump system	73
3.7	Pump curve for the pump selected for 30 m ³ /h	74
3.8	Sketch of pumping system in which the control valve fails	76
3.9	System resistance curve and pump curve showing the operation of the system	77
3.10	Pump curves and system curves showing the operation of the original system and the modified pump impeller	77
4.1	LCC comparison for the waste collection system	82
4.2	LCC comparison for the problem control valve system	85
6.1	New pumping system	96
6.2	Existing pump systems	97
A.1a	Operating duty point at $H_{\text{pump}} = H_{\text{syst}}$ for a rotodynamic pump	106
A.1b	Operating duty point at $H_{\text{pump}} = H_{\text{syst}}$ for a positive displacement pump	106
A.2	Example of simple piping system	107
A.3	System curve	109
A.4	Piping systems with the same static head	109
A.5	Piping system with $H_{\text{stat}} \approx 0$; $H_{\text{syst}} = H_j$	110
A.6	System with $H_j \approx 0$	110
A.7	Resultant pump curve for series operation	111
A.8	Parallel pump operation	111

A.9	Parallel operation of two similar pumps with different system curves.	112
A.10	Pumping systems with different static heads	112
A.11	System curve with varying static head	113
A.12	Consequences of incorrectly calculated pipe losses	114
A.13	The effect of deposits (scale, rust, etc.) on pipelines	115
A.14	The effect of varying levels.	116
A.15	The effect of adding margins to calculated system curve.	116
A.16	Branched circulation system.	118
A.17	Branched piping system, $H_{\text{stat}} = 0$	118
A.18	Branched pipe system with different static head	119
A.19	Branched piping system with positive suction static head	120
A.20	Pump performance by reduced impeller diameter	121
A.21	Pump performance by variable speed	122
A.22	Variable pitch propeller pumps.	123
A.23	Mixed-flow pumps with adjustable inlet guide vanes	123
A.24	Pump and system curves for more viscous liquids as compared with water.	124
A.25	Pump and system curves for water and pulp suspension	125
B.1	The duty point is the intersection between the pump and system curves: rotodynamic pump (RD); positive displacement pump (PD).	128
B.2	Flow as a function of time – operating curve	129
B.3	Duration curve of the flow.	129
B.4	Graphical integration method to determine mean rates of flow	130
B.5	Illustration of Equations B-1 and B-2	131
B.6	Control at (a) constant pressure, (b) constant flow, and (c) proportional level control	135
B.7	Pump and drive system	138
B.8a	Examples of performance curves for a speed regulated rotodynamic pump	139
B.8b	Performance curves for PD-pumps with speed regulation	139
B.9	Pump power requirement for speed-regulated rotodynamic pump with hydraulic coupling transmission	140

B.10	Typical stroke adjustable drive element of a reciprocating positive displacement pump	142
B.11	Power requirement for single stage rotodynamic pumps with flow control using various methods, in a system with a low ratio: H_{stat}/H_0	143
C.1	Typical single-stage, single-suction volute casing pump	145
C.2	Maximum attainable efficiencies, η_{max} , of single-stage, single-suction volute casing pumps dependent on specific speeds and rates of flow	147
C.3	Average attainable industrial pump efficiencies, η_{avg} , of single-stage, single-suction volute casing pumps dependent on specific speeds and rates of flow	148
E.1	Losses in a typical 75 kW induction motor.	181
E.2	Typical efficiencies of 2-pole, 3-phase asynchronous submersible motors	182
E.3	Loading profile for a circulator	183
E.4	(1) Uncontrolled circulators; (2) Circulators with voltage controlled motors; (3) Circulators with frequency controlled motors	184

List of Tables

1.1	Factor C_p/C_n for a single cost element after n years.	12
1.2	Discount factor (df) for constant yearly expenditures	13
2.1	Control methods – applications and limitations.	21
2.2	Application ranges of positive displacement pumps	33
2.3	Properties of commercially available PD pumps; PH/PS = hydraulic power /shaft power	34
2.4	Positive and negative aspects of specific transmissions.	43
3.1	Operation and annual operating cost of the three-branched piping system in the various operating modes	70
3.2	Work sheets (a) and (b) showing how the rate of flow is calculated by pumping down and filling a sump	72
3.3	Cost comparison for energy cost for the 60 m ³ /h (260 USgpm) and 30 m ³ /h (130 USgpm) pumps	75
3.4	Cost comparison for Options A through D in the system with a failing control valve.	78
B.1	Control methods – applications and limitations.	132

B.2 Some control parameters used for pumps	134
D.1 Summary of Case Histories	150
E.1 Positive and negative aspects of specific transmissions	194