

American National Standard for

Rotodynamic Pumps

Guideline for Operating Regions

Sponsor
Hydraulic Institute
www.Pumps.org

Approved January 5, 2024
American National Standards Institute, Inc.

Table of Contents

9.6.3	Operating regions	1
9.6.3.1	Introduction	1
9.6.3.1.1	Purpose	1
9.6.3.1.2	Scope	1
9.6.3.2	Definitions	1
9.6.3.2.1	Best efficiency point (BEP)	1
9.6.3.2.2	Specific speed.....	1
9.6.3.2.3	Suction specific speed	2
9.6.3.3	Preferred operating region (POR).....	2
9.6.3.3.1	Typical preferred operating region.....	2
9.6.3.3.2	Influence of the speed of rotation on the POR.....	3
9.6.3.4	Allowable operating region (AOR)	4
9.6.3.4.1	Factors affecting AOR.....	4
9.6.3.4.1.1	Hydraulic loads.....	4
9.6.3.4.1.1.1	Bearing life	4
9.6.3.4.1.1.2	Fatigue life of components.....	4
9.6.3.4.1.1.3	Internal mechanical contact	5
9.6.3.4.1.1.4	Shaft seal life.....	5
9.6.3.4.1.2	Thrust reversal	5
9.6.3.4.1.3	Temperature rise.....	5
9.6.3.4.1.4	Vibration	5
9.6.3.4.1.5	Sound pressure (noise) levels	6
9.6.3.4.1.6	Power limit.....	6
9.6.3.4.1.7	Liquid velocity.....	6
9.6.3.4.1.8	Pumpage and potential for clogging	7
9.6.3.4.1.9	Net positive suction head available (NPSHA) and NPSH margin	7
9.6.3.4.1.10	Pump curves with instabilities.....	8
9.6.3.4.1.10.1	Droop instability.....	9
9.6.3.4.1.10.2	Dip instability	9
9.6.3.4.1.11	Suction recirculation.....	10
9.6.3.4.1.12	Discharge recirculation	11
9.6.3.4.1.13	Maximum allowable working pressure	12
9.6.3.4.1.14	Speed of rotation.....	12
9.6.3.4.1.15	Fluid mixtures.....	12
9.6.3.4.2	AOR Boundaries with changes in operating conditions.....	12
9.6.3.4.3	Other factors affecting reliability.....	13
9.6.3.5	Relative life expectancy	14

9.6.3.6	Manufacturer deviations from guideline	14
9.6.3.7	Intermittent operation outside the AOR	15

Figures

9.6.3.3.2	Limits of POR vs. speed of rotation	3
9.6.3.4.1.6	Typical power curves vs. rate of flow for pumps of various specific speeds	6
9.6.3.4.1.9a	The AOR maximum rate of flow limited the intersection between the NPSHA and NPSHR plus minimum margin.	7
9.6.3.4.1.9b	AOR limited by NPSH with constant NPSHA	8
9.6.3.4.1.10.1	Head vs. rate of flow curve illustrating droop instability	9
9.6.3.4.1.10.2	Head vs. rate of flow curve illustrating a dip instability	10
9.6.3.4.1.11a	Estimated minimum rate of flow to avoid suction recirculation (metric units)	11
9.6.3.4.1.11b	Estimated minimum rate of flow to avoid suction recirculation (US customary units).....	11
9.6.3.4.1.14	Example of factors defining the boundary of the AOR for variable speed operation.....	13
9.6.3.3.3	Relative life expectancy vs. operating regions.....	14

Table

9.6.3.3.1	Preferred operating region related to specific speed	3
-----------	--	---